

# *The Water We Drink*

## **Annual Drinking Water Quality Report**

### **Cedar Bonnet Distribution System**

#### **For the Year 2023, Results from the Year 2022**

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources.

**If you are a landlord, you must distribute this Drinking Water Quality Report to every tenant as soon as practicable, but no later than three business days after receipt. Delivery must be done by hand, mail, or email, and by posting the information in a prominent location at the entrance of each rental premises, pursuant to section #3 of NJ P.L. 2021, c.82 (C.58:12A-12.4 et seq.).**

We are committed to ensuring the quality of your water. We purchase our water from the Ship Bottom Water Department. Their source of water is two wells that draw groundwater, from the Atlantic City Aquifer, over 600 feet deep. The New Jersey Department of Environmental Protection (NJDEP) has prepared Source Water Assessment Reports and Summaries for all public water systems. Further information on the Source Water Assessment Program can be obtained by logging onto NJDEP's source water assessment web site at [WWW.state.nj.us/dep/swap](http://WWW.state.nj.us/dep/swap) or by contacting NJDEP's Bureau of Safe Drinking Water at (609) 292-5550. Ship Bottom Water Department's source water assessment, susceptibility ratings and a list of potential contaminant sources is included.

**Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).**

The Ship Bottom Water Department and the Stafford Township Water & Sewer Utility Department routinely monitor for contaminants in your drinking water according to Federal and State laws. The tables show the results of their monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2022. The state allows monitoring for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. For a short period of time in 2021, when Ship Bottom's new drinking water treatment plant was under construction, their drinking water was supplied by the Surf City Water Department. Surf City's drinking water test result information is included.

<b>Cedar Bonnet Distribution System Test Results PWS ID #NJ1530003</b>						
<b>Contaminant</b>	<b>Violation Y/N</b>	<b>Level Detected</b>	<b>Units of Measure -ment</b>	<b>MC LG</b>	<b>MCL</b>	<b>Likely Source of Contamination</b>
<b>Inorganic Contaminants:</b>						
Copper Test results Yr. 2022 Result at 90 <sup>th</sup> Percentile	N	ND No samples exceeded the action level	ppm	1.3	AL=1.3	Corrosion of household plumbing; Erosion of natural deposits.
Lead Test results Yr. 2022 Result at 90 <sup>th</sup> Percentile	N	ND No samples exceeded the action level.	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfection Byproducts:</b>						
TTHMs Total Trihalomethanes Test results Yr. 2022	N	5	ppb	N/A	80	Byproduct of drinking water disinfection
HAA5s Haloacetic Acids Test results Yr. 2022	N	1	ppb	N/A	60	Byproduct of drinking water disinfection
<b>Regulated Disinfectants</b>	<b>Level Detected</b>		<b>MRDL</b>		<b>MRDLG</b>	
Chlorine Test results Yr. 2022	Range = 0.4 – 0.8 ppm Average = 0.7 ppm		4.0 ppm		4.0 ppm	

**Chlorine:** Water additive used to control microbes

If you have any questions about this report or concerning your water utility, please contact the Stafford Township Water & Sewer Utility Department at 609-597-1000, extension #8588. Our office hours are 8:30 a.m. to 4:30 p.m. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled Stafford Township Council meetings, which are held on the first and third Tuesdays of each month at the Municipal Complex, 260 East Bay Avenue, Manahawkin, in the Council Room. Meetings begin at 7:00 p.m.

**We at Stafford Township Water & Sewer Utility Department work hard to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office if you have questions.**

### Ship Bottom Water Department Test Results PWS ID #NJ1528001

Contaminant	Violation Y/N	Level Detected	Units of Measurement	MC LG	MCL	Likely Source of Contamination
<b>Radioactive Contaminants:</b>						
Combined Radium 228 & 226 Test results Yr. 2017	N	1.8	pCi/l	0	5	Erosion of natural deposits
<b>Inorganic Contaminants:</b>						
Copper Test results Yr. 2021 Result at 90 <sup>th</sup> Percentile	N	0.13 No samples exceeded the action level	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead Test results Yr. 2021 Result at 90 <sup>th</sup> Percentile	N	ND No samples exceeded the action level	ppb	0	AL= 15	Corrosion of household plumbing systems, erosion of natural deposits
<b>Disinfection By-Products:</b>						
TTHM Total Trihalomethanes Test results Yr. 2022	N	Range = 1 - 3 Highest detect = 3	ppb	N/A	80	By-product of drinking water disinfection
HAA5 Haloacetic Acids Test results Yr. 2022	N	Range = 2 Highest detect = 2	ppb	N/A	60	By-product of drinking water disinfection
<b>Regulated Disinfectants</b>		<b>Level Detected</b>		<b>MRDL</b>		<b>MRDLG</b>
Chlorine Test results Yr. 2022		Range = 0.7 – 1.0 ppm Average = 0.8 ppm		4.0 ppm		4.0 ppm

**Chlorine:** Water additive used to control microbes

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

To ensure the continued quality of the drinking water, sodium hypo-chloride is used for disinfection and lime for PH adjustment. The Safe Drinking Water Act regulations allow monitoring waivers to reduce or eliminate the monitoring requirements for asbestos, volatile organic chemicals and synthetic organic chemicals. The Ship Bottom Water Department received a monitoring waiver for synthetic organic chemicals.

In the tables, you might find some terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal -The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Action Level - the concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

### **Sources of Lead in Drinking Water**

The Stafford Township Water & Sewer Utility Department and the Ship Bottom Water Department are responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. Although most lead exposure occurs from inhaling dust or from contaminated soil, or when children eat paint chips, the U.S. Environmental Protection Agency (USEPA) estimates that 10 to 20 percent of human exposure to lead may come from lead in drinking water. Infants who consume mostly mixed formula can receive 40 percent to 60 percent of their exposure to lead from drinking water. Lead is rarely found in the source of your drinking water but enters tap water through corrosion, or wearing away, of materials containing lead in the water distribution system and household plumbing materials. These materials include lead-based solder used to join copper pipes, brass, and chrome-brass faucets, and in some cases, service lines made of or lined with lead. New brass faucets, fittings, and valves, including those advertised as "lead-free", may still contain a small percentage of lead, and contribute lead to drinking water. The law currently allows end-use brass fixtures, such as faucets, with up to 0.25 percent lead to be labeled as "lead free". However, prior to January 4, 2014, "lead free" allowed up to 8 percent lead content of the wetted surfaces of plumbing products including those labeled National Sanitation Foundation (NSF) certified. Visit the NSF website at [www.nsf.org](http://www.nsf.org) to learn more about lead-containing plumbing fixtures. Consumers should be aware of this when choosing fixtures and take appropriate precautions. When water stands in lead service lines, lead pipes, or plumbing systems containing lead for several hours or more, the lead may dissolve into your drinking water. This means the first water drawn from the tap in the morning, or later in the afternoon if the water has not been used all day, can contain fairly high levels of lead.

### **Steps You Can Take to Reduce Exposure to Lead in Drinking Water**

For a full list of steps visit: <https://www.state.nj.us/dep/watersupply/dwc-lead-consumer.html>

**Run the cold water to flush out lead.** Let the water run from the tap before using it for drinking or cooking any time the water in the faucet has gone unused for more than six hours. The longer the water resides in plumbing the more lead it may contain. Flushing the tap means running the cold-water faucet. Let the water run from the cold-water tap based on the length of the lead service line and the plumbing configuration in your home. In other words, the larger the home or building and the greater the distance to the water main (in the street), the more water it will take to flush properly. Although toilet flushing or showering flushes water through a portion of the plumbing system, you still need to flush the water in each faucet before using it for drinking or cooking. Flushing tap water is a simple and inexpensive measure you can take to protect your health. It usually uses less than one gallon of water.

**Use cold, flushed water for cooking and preparing baby formula.** Because lead from lead-containing plumbing materials and pipes can dissolve into hot water more easily than cold water, never drink, cook, or prepare beverages including baby formula using hot water from the tap. If you have not had your water sampled or if you know, it is recommended that bottled or filtered water be used for drinking and preparing baby formula. If you need hot water, draw water from the cold tap and then heat it.

**Do not boil water to remove lead.** Boiling water will not reduce lead; however, it is still safe to wash dishes and do laundry. Lead will not soak into dishware or most clothes.

**Use alternative sources or treatment of water.** You may want to consider purchasing bottled water or a water filter. Read the package to be sure the filter is approved to reduce lead or contact NSF International at 800-NSF-8010 or [www.nsf.org](http://www.nsf.org) for information on performance standards for water filters.

**Determine if you have interior lead plumbing or solder.** If your home/building was constructed prior to 1987, it is important to determine if interior lead solder or lead pipes are present. You can check yourself, hire a licensed plumber, or check with your landlord.

**Replace plumbing fixtures and service lines containing lead.** Replace brass faucets, fittings, and valves that do not meet the current definition of "lead free" from 2014 (as explained above). Visit the NSF website at [www.nsf.org](http://www.nsf.org) to learn more about lead-containing plumbing fixtures.

**Remove and clean aerators/screens on plumbing fixtures.** Over time, particles and sediment can collect in the aerator screen. Regularly remove and clean aerators screens located at the tip of faucets and remove any particles.

**Test your water for lead.** Please call 609-597-1000, ext. 8588, to find out how to get your water tested for lead. Testing is essential because you cannot see, taste, or smell lead in drinking water.

**Get your child tested.** Contact your local health department or healthcare provider to find out how you can get your child tested for lead if you are concerned about lead exposure. New Jersey law requires that children be tested for lead in their blood at both 1 and 2 years of age and before they are 6 years old if they have never been tested before or if they have been exposed to a known source of lead.

**Have an electrician check your wiring.** If grounding wires from the electrical system are attached to your pipes, corrosion may be greater. Check with a licensed electrician or your local electrical code to determine if your wiring can be grounded elsewhere. DO NOT attempt to change the wiring yourself because improper grounding can cause electrical shock and fire hazards.

**Water softeners and reverse osmosis units** will remove lead from water but can also make the water more corrosive to lead solder and plumbing by removing certain minerals; therefore, the installation of these treatment units at the point of entry into homes with lead plumbing should only be done under supervision of a qualified water treatment professional.

### **Health Effects of Lead**

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys and can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life. During pregnancy, the child receives lead from the mother's bones, which may affect brain development. Contact your local health department or healthcare provider to find out how you can get your child tested for lead if you are concerned about lead exposure. You can find out more about how to get your child tested and how to pay for it at <https://www.state.nj.us/health/childhoodlead/testing.shtml>.

### **Special Notice:**

In July 2022; an Updated Drinking Water Service Line Inventory, a Lead Service Line Replacement Plan and an Annual Lead Service Line Replacement Progress Report was to be submitted to the New Jersey Department of Environmental Protection (NJDEP). The Ship Bottom Water Department was inadvertently late in submitting their Annual Lead Service Line Replacement Progress Report and received a reporting violation. Once this information was received by NJDEP, the violation was returned to compliance on 1/31/2023.

### **Special Notice:**

Lead Tap Monitoring Results. All Water systems must provide a notice of the individual tap results from Lead Tap Monitoring to the persons served by the water system at the specific sampling site from which the sample was taken. This notice must be provided no later than 30 days after learning of the tap monitoring results. The Ship Bottom Water Department sampled in August of 2021, but we were late distributing these notices. Once this information was received by NJDEP, the violation was returned to compliance on 6/15/2022.

In July 2021, P.L.2021, Ch.183 (Law) was enacted, requiring all community water systems to replace lead service lines in their service area within 10 years. Under the law, the Stafford Township Water & Sewer Utility Department is required to notify customers, non-paying consumers, and any off-site owner of a property (e.g., landlord) when it is known they are served by a lead service line\*. Our service line inventory is available on our website at [www.staffordnj.gov](http://www.staffordnj.gov), or upon request.

### Ship Bottom Water Department - PWSID # NJ1528001

Ship Bottom Water Department is a public community water system consisting of 2 active wells.

This system's source water comes from the following aquifer: Atlantic City "800-foot" Sand Aquifer System.

This system can purchase water from the following water systems: Long Beach Township Water Department, Surf City Water Department.

### Susceptibility Ratings for Ship Bottom Water Department Sources

The table below illustrates the susceptibility ratings for the seven contaminant categories (and radon) for each source in the system. The table provides the number of wells and intakes that rated high (H), medium (M), or low (L) for each contaminant category. For susceptibility ratings of purchased water, refer to the specific water system's source water assessment report.

The seven contaminant categories are defined at the bottom of this page. DEP considered all surface water highly susceptible to pathogens, therefore all intakes received a high rating for the pathogen category. For the purpose of Source Water Assessment Program, radionuclides are more of a concern for ground water than surface water. As a result, surface water intakes' susceptibility to radionuclides was not determined and they all received a low rating.

**If a system is rated highly susceptible for a contaminant category, it does not mean a customer is or will be consuming contaminated drinking water.** The rating reflects the potential for contamination of source water, not the existence of contamination. Public water systems are required to monitor for regulated contaminants and to install treatment if any contaminants are detected at frequencies and concentrations above allowable levels. As a result of the assessments, DEP may customize (change existing) monitoring schedules based on the susceptibility ratings.

Sources	Pathogens			Nutrients			Pesticides			Volatile Organic Compounds			Inorganics			Radionuclides			Radon			Disinfection Byproduct Precursors		
	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L
Wells - 2			2			2			2			2			2			2			2			2

**Pathogens:** Disease-causing organisms such as bacteria and viruses. Common sources are animal and human fecal wastes.

**Nutrients:** Compounds, minerals and elements that aid growth, that are both naturally occurring and man-made. Examples include nitrogen and phosphorus.

**Volatile Organic Compounds:** Man-made chemicals used as solvents, degreasers, and gasoline components. Examples include benzene, methyl tertiary butyl ether (MTBE), and vinyl chloride.

**Pesticides:** Man-made chemicals used to control pests, weeds and fungus. Common sources include land application and manufacturing centers of pesticides. Examples include herbicides such as atrazine, and insecticides such as chlordane.

**Inorganics:** Mineral-based compounds that are both naturally occurring and man-made. Examples include arsenic, asbestos, copper, lead, and nitrate.

**Radionuclides:** Radioactive substances that are both naturally occurring and man-made. Examples include radium and uranium.

**Radon:** Colorless, odorless, cancer-causing gas that occurs naturally in the environment. For more information go to <http://www.nj.gov/dep/rpp/radon/index.htm> or call (800) 648-0394.

**Disinfection Byproduct Precursors:** A common source is naturally occurring organic matter in surface water. Disinfection byproducts are formed when the disinfectants (usually chlorine) used to kill pathogens react with dissolved organic material (for example leaves) present in surface water.